



Environmental Control Systems, Inc.

Environmental Engineers and Management Consultants

December 27, 2019

Mr. Matt Melady
Director of Operations
Harambee Institute of Science & Technology Charter School
640 N. 66th Street
Philadelphia, PA 19151

Re: Lead in Drinking Water Sampling Results

Dear Mr. Melady:

On December 19, 2019, three (3) potable water outlets and seven (7) drinking water fountains were tested for Lead in Drinking Water at the Harambee Institute of Science & Technology Charter School. "First Draw" samples were collected in accordance with EPA protocol listed in the 3T's for Reducing Lead in Drinking Water in Schools, revised October 2018.

Analysis was performed by EMSL, an EPA accredited laboratory. Results are based on the School District of Philadelphia requirements of 10 ppb which are more strict than PDE and EPA recommended action level of 15 parts per billion (ppb) for lead in schools based on a 250 ml sample.

All results are under the School District of Philadelphia action limit of 10 ppb and the PA Act 39, PDE and EPA action limit of 15 ppb.

Please let me know if you have any questions.

Cordially,

Barbara Lippmann
President

Enclosure: